

Approval Number 2305549  
Test Report: J-00460226 & J-00460227



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

4<sup>th</sup> July 2023

Interplast SA  
Komotini Industrial Zone,  
Komotini P.C. 69100,  
Greece

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)  
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYPROPYLENE- COMPONENTS.**

**5260**

'Aqua Plus Fibreglass Triple Layer PPR-CT Pipe'.

Triple layered, extruded pipe consisting of a green coloured PP inner layer, grey coloured PP/fibreglass middle layer and green coloured PP outer layer.

For use with water up to 23°C.

**APPROVAL NUMBER: 2305549**  
**APPROVAL HOLDER: INTERPLAST SA**

The Scheme reserves the right to review approval.  
Approval 2305549 is valid between May 2023 and May 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

**Ian Hughes**  
**WRAS Approvals Manager**